

Approval Number 2208564
Test Report: MA7635/R 1 & 2



Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

2nd September 2022

Teadit International Produktions GmbH
Europastrasse 12,
6322 Kirchbichl,
Austria

**WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

POLYTETRAFLUOROETHYLENE (PTFE)- COMPONENTS.

5294

'Monotape 12, 24 B, 24 BB, 24 HD & 25 BI'. White coloured PTFE tapes manufactured by extrusion, stretching and calendaring.

'24 SH, 20SH, 30SH & 28LS-LE'. White coloured PTFE gasket sheets manufactured by extrusion, stretching, sintering and calendaring.

For use with water up to 85°C.

APPROVAL NUMBER: 2208564

APPROVAL HOLDER: TEADIT INTERNATIONAL PRODUKTIONS GMBH

The Scheme reserves the right to review approval.

Approval 2208564 is valid between August 2022 and August 2027

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

A handwritten signature in blue ink, appearing to read 'Ian Hughes', with a stylized flourish at the end.

Ian Hughes
WRAS Approvals Manager